

Drinking Water Quality Management Plan (DWQMP) report

For the financial year: 2015-2016

Scheme: COEN

Cook Shire Council

SPID: 511

10 Furneaux St
Cooktown, Qld, 4895
07 4069 5444
mail@cook.qld.gov.au

COOK SHIRE COUNCIL - DRINKING WATER QUALITY MANAGEMENT PLAN ANNUAL REPORT

1. Introduction	4
2. Overview of Operations.....	4
3. Actions taken to implement the DWQMP	5
Revisions made to the operational monitoring program to assist in maintaining the compliance with water quality criteria in verification monitoring.....	5
Amendments made to the DWQMP.....	5
4. Compliance with water quality criteria for drinking water.....	6
Table 1.0A Summary of Treated Water quality details – Sampled from: Coen Reticulation, Analysed by: SGS - Cairns (NATA Certified).....	6
Table 1.0B Summary of All Treated Water quality details – Sampled from: Coen Reticulation, Analysed by: SGS - Cairns (NATA Certified).....	7
Table 1.1 Summary of E.coli & Coliforms monitoring – Sampled from: Coen Reticulation, Analysed by: SGS Cairns and Cook Shire Council’s Annan Lab *.....	8
Table 1.2 Location of sampling sites within Coen’s water reticulation network.	8
5. Notifications to the Regulator under sections 102 and 102A of the Act	9
6. Customer complaints related to water quality	9
Suspected Illness	9
Discoloured water	9
7. Findings and recommendations of the DWQMP auditor	9
8. Outcome of the review of the DWQMP and how issues raised have been addressed	9
Appendix A – Summary of compliance with water quality criteria	10
9. Verification Monitoring Results.....	11
Table 1.3A - Verification monitoring results (Raw Water) - Physical Chemical (Analysed by NATA Lab).....	11
Table 1.3B - Verification monitoring results (Raw Water) - Physical Chemical (Analysed by NATA Lab).....	12
Table 1.3C - Verification monitoring results (Raw Water) - Physical Chemical (Analysed by NATA Lab)	13
Table 1.3D - Verification monitoring results (Raw Water) - Metals (Analysed by NATA Lab)	14
Table 1.3E - Verification monitoring results (Raw Water) - Metals (Analysed by NATA Lab)	15
Table 1.3F - Verification monitoring results (Raw Water) - Metals (Analysed by NATA Lab).....	16
Table 1.3G - Verification monitoring results (Treated Water) - Physical Chemical (Analysed by NATA Lab).....	17
Table 1.3H - Verification monitoring results (Treated Water) - Metals (Analysed by NATA Lab).....	18
Table 1.3I - Verification monitoring results (Treated Water) - Metals (Analysed by NATA Lab).....	19
Table 2 - Reticulation <i>E. coli</i> verification monitoring	20
Appendix B – Implementation of the DWQMP Risk Management Improvement Program.....	21
Appendix C – Implementation of the 2016/17 Budgeted Capital Works Improvement Program ..	22

Glossary of terms

ADWG 2011	Australian Drinking Water Guidelines (2011). Published by the National Health and Medical Research Council of Australia
<i>E. coli</i>	<i>Escherichia coli</i> , a bacterium which is considered to indicate the presence of faecal contamination and therefore potential health risk
mg/L	Milligrams per litre
NTU	Nephelometric Turbidity Units
MPN/100mL	Most probable number per 100 millilitres
<	Less than
>	Greater than
NATA Lab	Accredited by the National Association of Testing Authorities of Australia

1. Introduction

This report documents the performance of Cook Shire Council's drinking water service with respect to water quality and performance in implementing the actions detailed in the drinking water quality management plan (DWQMP) as required under the Water Supply (Safety and Reliability) Act 2008 (the Act).

The report assists the Regulator to determine whether the approved DWQMP and any approval conditions have been complied with and provides a mechanism for providers to report publicly on their performance in managing drinking water quality.

2. Overview of Operations

One of Coen's Water sources is from the Lankelly Creek which originates high in the rainforest approximately 15km to the east of the township. The catchment area of approx. 5049 ha is in pristine rainforest and due to the terrain has very limited human impact. A second source is from the Coen Dam, this is an ex mining dam, it does contain elevated levels of natural arsenic and iron, and in the past has had blue green algae blooms during the warmer months, this is not an annual event, but has happened in the years when seasonal conditions have been favourable. The algal blooms have been decreasing in intensity since Cook Shire Council fenced the perimeter of the dam, this has effectively kept wandering stock out of the dam and considerably reduced the nutrient levels. The third source is from the Coen borefields consisting of 3 bores located in the township.

Dependent upon the water source, some or all of the following treatment processes are used

- Aeration
- Dissolved Air Flotation
- Filtration (Pressure filter and /or Microfiltration unit)
- Chlorination

The treated water is pumped to a 0.445ML Reservoir on site, and then gravity feeds directly into the Coen reticulation

Coen currently has 117 Service connections which can be broken down to approximately:

Residential 60%

Commercial / Industrial 10%

With the remaining 30% being Government, Council, Institutional or Other

3. Actions taken to implement the DWQMP

The water sampling schedule is now more rigorously adhered to than prior to the plan being approved, a database was set up with all the schedule details in it, this was given to all that collect samples. By typing in the "Week start date" a list of the required samples for that week is displayed, and can be printed. It tells the sample collectors the following information

- Week Commencing Date
- Type of sample to be collected e.g. E.coli & Total Coliforms, Fluoride, Reticulation Metals - (Suite of 15) etc
- Scheme e.g. Cooktown, Lakeland Laura or Coen
- Who the sample is to be analysed by e.g. CSC Annan Lab., or NATA Lab., or both
- A description e.g. 3 Samples from Reticulation - Sample sites listed, 1 T/Plant Final Water Sample
- Sample Site - displays where the sample is to be taken from
- Whether the sample is a Verification Sample or otherwise.

Verification samples are collected in the same manner as any sample, however a larger sample is required, as the same sample is analysed by both Cook Shire as well as by a NATA lab. We then compare the CSC results against the results from the NATA Lab, to ensure that our testing methods are getting valid results

A copy of the Sampling Matrix was sent to the NATA Lab, they now supply the appropriate sample bottles for each week as well as each scheme month by month. At approx the 3rd week of every month we receive the entire sample bottles for the following month. This seems to be working well

Revisions made to the operational monitoring program to assist in maintaining the compliance with water quality criteria in verification monitoring.

To date there has been no revisions to the operational monitoring since the DWQMP was approved

Amendments made to the DWQMP

A thorough review of the DWQMP was conducted with some extensive alterations being made to the existing plan.

The revised plan was submitted to the Regulator on 26th April 2016

The revised plan, as submitted, was approved by the Regulator on 27th July 2016

**COOK SHIRE COUNCIL - DRINKING WATER QUALITY MANAGEMENT PLAN
ANNUAL REPORT**

4. Compliance with water quality criteria for drinking water

Table 1.0A Summary of Treated Water quality details – Sampled from: Coen Reticulation, Analysed by: SGS - Cairns (NATA Certified)

Sample Period 1/7/2015 - 30/6/2016

Physical and Chemical Characteristics

Parameter	Unit	No of Samples collected	Summary of Results			ADWG Guidelines Value (2011)	No of Samples exceeding ADWG	
			Max. Value	Min. Value	Avg. Value		Health	Aesthetic
Alkalinity	mg/L as CaCO ₃	4	28	10	17.8	-	-	-
Calcium	mg/L	4	6.3	0.6	3.0	-	-	-
Chloride	mg/L	4	20.0	14.0	18.0	< 250 - mg/L	-	0
Colour	HU	4	14.0	5.0	9.8	< 15 - HU	-	0
Electrical Conductance	µs/cm	4	140.0	52.0	106.8	-	-	-
Fluoride	mg/L	4	0.20	0.09	0.14	< 1.5 - mg/L	0	-
Magnesium	mg/L	4	1.5	0.7	1.0	-	-	-
pH	pH units	4	7.6	6.8	7.2	6.5-8.5	-	0
Potassium	mg/L	4	1.5	1.0	1.2	-	-	-
Salinity	mg/L	4	92.0	34.0	69.0	-	-	-
SAR		4	2.3	1.7	2.1	-	-	-
Silica Soluble	mg/L	4	18.0	11.0	15.0	< 80 - mg/L	-	0
Sodium	mg/L	4	21.0	8.4	15.6	< 180 - mg/L	-	0
Sulphate	mg/L	4	14.0	0.8	7.4	< 250 - mg/L	0	0
Total Dissolved Solids	mg/L	4	84.0	31.0	63.5	< 600 - mg/L	-	0
Total Hardness	mg/L as CaCO ₃	4	19.0	4.0	11.5	< 200 - mg/L	-	0
Turbidity	NTU	4	1.2	0.5	0.8	< 5 - NTU	-	0

Samples collected from set sample points throughout the Reticulation including high and low flow areas.

Each quarter a sample is collected from 1 location in the Reticulation, systematically rotated to ensure all sample points are captured

COOK SHIRE COUNCIL - DRINKING WATER QUALITY MANAGEMENT PLAN ANNUAL REPORT

Table 1.0B Summary of All Treated Water quality details – Sampled from: Coen Reticulation, Analysed by: SGS - Cairns (NATA Certified)

Sample Period 1/7/2015 - 30/6/2016

Metals

Parameter	Unit	No of Samples collected	Summary of Results			ADWQ Guidelines Value (2011)	No of Samples exceeding ADWG	
			Max. Value	Min. Value	Avg. Value		Health	Aesthetic
Arsenic	mg/L	5	0.004	0.002	0.003	0.01-mg/L	0	-
Barium	mg/L	5	0.01	0.005	0.0075	< 2 - mg/L	0	-
Beryllium	mg/L	5	0.0001	0.0001	0.0001	< 0.006 - mg/L	0	-
Cadmium	mg/L	5	0.0001	0.0001	0.0001	< 0.002 - mg/L	0	-
Chromium	mg/L	5	0.001	0.001	0.001	< 0.05 - mg/L	0	-
Cobalt	mg/L	5	0.001	0.001	0.001	-	-	-
Copper	mg/L	5	0.015	0.001	0.0072	< 2 - mg/L	0	0
Iron	mg/L	5	0.079	0.005	0.029	< 0.3 - mg/L	-	0
Lead	mg/L	5	0.001	0.001	0.001	< 0.01 - mg/L	0	-
Manganese	mg/L	5	0.011	0.005	0.0065	< 0.1 - mg/L	0	0
Mercury	mg/L	5	<0.00005	<0.00005	<0.00005	< 0.001 -mg/L	0	-
Nickel	mg/L	5	0.001	0.001	0.001	< 0.02 - mg/L	0	-
Selenium	mg/L	5	0.003	0.003	0.003	< 0.01 - mg/L	0	-
Vanadium	mg/L	5	0.005	0.001	0.0018	-	-	-
Zinc	mg/L	5	0.005	0.005	0.005	< 3.0 - mg/L	-	0

Samples collected from set sample points throughout the Reticulation including high and low flow areas.

Each quarter a sample is collected from 1 location in the Reticulation, systematically rotated to ensure all sample points are captured

This period there was 1 additional “Metals” sample collected and analysed, this was mistakenly sent off by the operator

COOK SHIRE COUNCIL - DRINKING WATER QUALITY MANAGEMENT PLAN ANNUAL REPORT

Table 1.1 Summary of E.coli & Coliforms monitoring – Sampled from: Coen Reticulation, Analysed by: SGS Cairns and Cook Shire Council’s Annan Lab *
Sample Period 1/7/2015 - 30/6/2016

	Parameter	Sampling Location	Time Period	No of samples taken in time period	Summary of results		Australian Drinking Water Guidelines guideline value (2011)	No of samples exceeding Australian Drinking Water Guidelines guideline value
					No of Samples where E.coli detected	No of Samples where Coliforms detected		
E.coli and Coliforms	E.coli – MPN/100ml	Various set Locations within the Coen Reticulation	July 2015 – June 2016	153	0	-	0	0
	Coliforms – MPN/100ml			153	-	2	-	0

None of the samples collected had E.coli detected, 2 samples had 1 coliform each detected.

Table 1.2 Location of sampling sites within Coen’s water reticulation network.

Sample Location Name	Street Name	Site Chosen Because	GPS Coordinates *
Kindy Corner	Cnr Peninsular Dev. Rd and Reservoir Rd	Water Main “Teas” at this point and close to the Kindy	13°56'38.31"S - 143°12'11.52"E
Heritage House	Regent Street	Ease of access and in the centre of the town	13°56'39.41"S - 143°11'56.84"E
Coen School	Taylor Street	Central, and close to the School	13°56'43.83"S - 143°11'59.12"E
Cultural Centre	Shephard Street	Towards the “End of Line”	13°56'58.55"S - 143°11'53.53"E
Guest House	Regent Street	Central and “Ease of Access”	13°56'39.19"S - 143°12'2.22"E
Old National Parks Office	Coleman Close	Towards the “End of Line”	13°56'23.50"S - 143°11'57.44"E
Lutheran Church	Off Port Stewart Road	Towards the “End of Line”	13°56'58.37"S - 143°12'1.14"E
CSC Depot	Lankelly Drive	Towards the “End of Line”	13°56'27.13"S - 143°12'17.21"E

All reticulation sampling for all parameters are collected from these fixed sites for the reasons listed

5. Notifications to the Regulator under sections 102 and 102A of the Act

For the financial year 2015-2016 there were nil instances where the Regulator needed to be notified under sections 102 or 102A of the Act. There was no detection of E. coli – an organism that may not directly represent a hazard to human health, in any samples but indicates the presence of recent faecal contamination. There were nil incidents that required a “Boil Water Alert” to be issued, or “Do not drink Water” notices displayed in the community.

6. Customer complaints related to water quality

Cook Shire Council is required to report on the number of complaints, general details of complaints, and the responses undertaken.

Cook Shire maintains a “Register of Complaints” which includes Water & Wastewater. Customer Services officers generally receive the initial complaints, which if it’s in the form of a letter, or email, then it is then filed in the “TRIM” Database, a Task is then generated from “Authority” and dispersed to the relevant officer/s for actioning. The relevant officer/s must record the actioned details in “Authority” to complete the Task. So a record of the complaint and the action taken to rectify the problem is all recorded. At the end, the complainant is notified of the outcome of the original complaint

A search of both the “Trim” database and the CRM (Customer Request Management) in “Authority” for the financial year 2015-2016 has located zero Customer Complaints regarding Water Quality

Suspected Illness

Cook Shire Council (Water & Wastewater) are not aware of any customers who suspect their water from the Coen Reticulated Water Supply may in some way be associated with an illness or sickness they are experiencing.

Discoloured water

Cook Shire Council had not had any Discoloured water incidents / complaints for the Coen Reticulated Water Supply in this reporting period

Taste and odour

Cook Shire Council had not had any Taste & Odour water incidents / complaints for the Coen Reticulated Water Supply in this reporting period

7. Findings and recommendations of the DWQMP auditor

Cook Shire Council was not required to conduct a regular audit of the approved DWQMP during the current reporting period, 2015/2016

The first regular audit of Cook Shire’s DWQMP’s must be conducted by 30th June 2017

8. Outcome of the review of the DWQMP and how issues raised have been addressed

Cook Shire Councils first review of the DWQMP’s was completed prior to 31st March 2016.

Michael Lawrence was engaged through Bligh Tanner to conduct the first review, in conjunction with Cook Shire Officers. Michael is highly qualified and experienced to perform these reviews, which in our case was quite extensive with some major changes to the original plan

The revised plans were submitted to the Regulator on 26/4/2016. A notification of approval of the “As submitted” plan was received on the 3/8/2016

Appendix A – Summary of compliance with water quality criteria

Cook Shire Council has a Water sampling Schedule which shows which samples are to be collected and sent off for analysis on a weekly basis. This is broken up into the 4 water Schemes. The Coen operator is responsible for the collection and dispatch of all the Coen Sampling, whilst the Cooktown Reticulation team is responsible for the collection and dispatch of all the Cooktown, Lakeland and Laura Samples.

Verification monitoring has generally been carried out as per the stated program; some samples have had to be collected on the week before, or after, the dates in the Water Sampling Schedule, due to operational issues / commitments

Being in a remote location, the nearest NATA laboratories are located in Cairns which is well over 400km (Direct Line) from Coen, this has presented various challenges over the years in getting samples to the laboratory.

In the past samples collected have:

- Been taken to the airport only to be told that the flight was cancelled (This seriously affects bacteriological samples)
- Courier company in Cairns failed to pick up the samples at all
- Courier company in Cairns picks up samples but fails to deliver on time
- Airline or Courier Company completely losses esky containing water samples
- Airline ceases operations into Coen (without notice)

So despite our best intentions, not all samples that are collected get to be analysed due to reasons beyond our control. This becomes a huge inconvenience and cost to council to have to re-sample

Verification monitoring is a tool to verify that the water we are producing and suppling to consumers is Safe drinking water and that it complies with the ADWG's

**COOK SHIRE COUNCIL - DRINKING WATER QUALITY MANAGEMENT PLAN
ANNUAL REPORT**

9. Verification Monitoring Results

Table 1.3A - Verification monitoring results (Raw Water) - Physical Chemical (Analysed by NATA Lab)

Sample Period 1/7/2015 - 30/6/2016

Source: Lankelly Creek

Scheme component	Parameter Physical / Chemical	Units	Total No. samples collected	Min	Max	Average (Mean)	Limit of reporting
Raw Water	Alkalinity as CaCO ₃	mg/L as CaCO ₃	2	6.0	7.0	6.5	5
	Calcium, Ca	mg/L	2	0.5	1.2	0.85	0.05
	Chloride, Cl	mg/L	2	12	14	13	1
	Colour Apparent	PCU	2	20	70	45	5
	Conductivity @ 25°C	uS/cm	2	50	67	58.5	5
	Fluoride, by ISE	mg/L	2	<0.05	<0.05	<0.05	0.05
	L.I.		2	-3.8	-3.4	-3.6	-10
	Magnesium, Mg	mg/L	2	0.7	1.1	0.90	0.05
	pH	pH units	2	6.9	6.9	6.9	0.1
	Potassium, K	mg/L	2	1.0	1.5	1.25	0.05
	Salinity	mg/L	2	33	44	38.50	10
	SAR		2	1.5	1.7	1.6	
	Silica	mg/L	2	12	15	13.5	0.05
	Sodium, Na	mg/L	2	8.1	9.0	8.55	05
	Sulphate, SO ₄	mg/L	2	0.7	1.5	1.10	0.5
	TDS	mg/L	2	30	40	35	10
	Total Hardness	mg/L as CaCO ₃	2	5	7	6	1
Turbidity	NTU	2	0.8	3	1.90	0.5	

Analysed by SGS Cairns

Lankelly Creek is a seasonal Creek, and generally only runs for 6-8 months, with the first couple of months being highly turbid and difficult to treat, after that when it settles down it produces a good quality water

COOK SHIRE COUNCIL - DRINKING WATER QUALITY MANAGEMENT PLAN ANNUAL REPORT

Table 1.3B - Verification monitoring results (Raw Water) - Physical Chemical (Analysed by NATA Lab)

Sample Period 1/7/2015 - 30/6/2016

Source: Coen Dam

Scheme component	Parameter Physical / Chemical	Units	Total No. samples collected	Min	Max	Average (Mean)	Limit of reporting
Raw Water	Alkalinity as CaCO ₃	mg/L as CaCO ₃	4	6.0	26.0	15.5	5
	Calcium, Ca	mg/L	4	0.52	3.30	2.01	0.05
	Chloride, Cl	mg/L	4	11.0	14.0	12.75	1
	Colour Apparent	PCU	4	20	70	41.25	5
	Conductivity @ 25°C	uS/cm	4	50	94	72.75	5
	Fluoride, by ISE	mg/L	4	0.20	0.23	0.22	0.05
	L.I.		4	-3.80	-2.10	-3.10	-10
	Magnesium, Mg	mg/L	4	.73	1.40	1.11	0.05
	pH	pH units	4	6.9	7.3	7.1	0.1
	Potassium, K	mg/L	4	0.70	1.50	1.01	0.05
	Salinity	mg/L	4	33.0	61.0	47.50	10
	SAR		4	1.40	1.70	1.53	
	Silica	mg/L	4	9.10	15	11.78	0.05
	Sodium, Na	mg/L	4	8.10	13.0	10.33	05
	Sulphate, SO ₄	mg/L	4	0.50	1.50	0.90	0.5
	TDS	mg/L	4	30.0	56.0	43.50	10
	Total Hardness	mg/L as CaCO ₃	4	7.00	14.0	11.0	1
Turbidity	NTU	4	0.8	7.70	3.73	0.5	

Analysed by SGS Cairns

Coen Dam is used after the Lankelly creek dries up, requires more treatment than the Lankelly, but again produces good quality water.

COOK SHIRE COUNCIL - DRINKING WATER QUALITY MANAGEMENT PLAN ANNUAL REPORT

Table 1.3C - Verification monitoring results (Raw Water) - Physical Chemical (Analysed by NATA Lab)

Sample Period 1/7/2015 - 30/6/2016

Source: Coen Bores

Scheme component	Parameter Physical / Chemical	Units	Total No. samples collected	Min	Max	Average (Mean)	Limit of reporting
Raw Water	Alkalinity as CaCO ₃	mg/L as CaCO ₃	4	6.0	26.0	15.5	5
	Calcium, Ca	mg/L	4	0.52	3.30	2.01	0.05
	Chloride, Cl	mg/L	4	11.0	14.0	12.75	1
	Colour Apparent	PCU	4	20	70	41.25	5
	Conductivity @ 25°C	uS/cm	4	50	94	72.75	5
	Fluoride, by ISE	mg/L	4	0.20	0.23	0.22	0.05
	L.I.		4	-3.80	-2.10	-3.10	-10
	Magnesium, Mg	mg/L	4	.73	1.40	1.11	0.05
	pH	pH units	4	6.9	7.3	7.1	0.1
	Potassium, K	mg/L	4	0.70	1.50	1.01	0.05
	Salinity	mg/L	4	33.0	61.0	47.50	10
	SAR		4	1.40	1.70	1.53	
	Silica	mg/L	4	9.10	15	11.78	0.05
	Sodium, Na	mg/L	4	8.10	13.0	10.33	05
	Sulphate, SO ₄	mg/L	4	0.50	1.50	0.90	0.5
	TDS	mg/L	4	30.0	56.0	43.50	10
	Total Hardness	mg/L as CaCO ₃	4	7.00	14.0	11.0	1
Turbidity	NTU	4	0.8	7.70	3.73	0.5	

Analysed by SGS Cairns

Coen Dam is used after the Lankelly creek dries up, requires more treatment than the Lankelly, but again produces good quality water.

**COOK SHIRE COUNCIL - DRINKING WATER QUALITY MANAGEMENT PLAN
ANNUAL REPORT**

Table 1.3D - Verification monitoring results (Raw Water) - Metals (Analysed by NATA Lab)

Sample Period 1/7/2015 - 30/6/2016

Source: Lankelly Creek

Scheme component	Parameter Metals	Units	Total No. samples collected	Min	Max	Average (Mean)	Limit of reporting
Raw Water	Arsenic	mg/L	2	<0.003	<0.003	<0.003	0.003
	Barium	mg/L	2	0.01	0.011	0.01	0.005
	Beryllium	mg/L	2	0.0001	0.0001	0.0001	0.0001
	Cadmium	mg/L	2	<0.0001	<0.0001	<0.0001	0.0001
	Chromium	mg/L	2	<0.001	<0.001	<0.001	0.001
	Cobalt	mg/L	2	<0.001	<0.001	<0.001	0.001
	Copper	mg/L	2	<0.001	<0.001	<0.001	0.001
	Iron	mg/L	2	0.20	0.23	0.215	0.005
	Lead	mg/L	2	<0.001	<0.001	<0.001	0.001
	Manganese	mg/L	2	<0.005	<0.005	<0.005	0.005
	Mercury	mg/L	2	<0.00005	<0.00005	<0.00005	0.00005
	Nickel	mg/L	2	<0.001	<0.001	<0.001	0.001
	Selenium	mg/L	2	<0.003	<0.003	<0.003	0.003
	Vanadium	mg/L	2	<0.01	<0.01	<0.01	0.001
	Zinc	mg/L	2	<0.01	<0.01	<0.01	0.005

Analysed by SGS Cairns

Samples collected in the first half of the year when the creek is flowing

**COOK SHIRE COUNCIL - DRINKING WATER QUALITY MANAGEMENT PLAN
ANNUAL REPORT**

Table 1.3E - Verification monitoring results (Raw Water) - Metals (Analysed by NATA Lab)

Sample Period 1/7/2015 - 30/6/2016

Source: Coen Dam

Scheme component	Parameter Metals	Units	Total No. samples collected	Min	Max	Average (Mean)	Limit of reporting
Raw Water	Arsenic	mg/L	8	0.0070	0.020	0.0133	0.003
	Barium	mg/L	4	0.01	0.024	0.017	0.005
	Beryllium	mg/L	4	<0.0001	<0.0001	<0.0001	0.0001
	Cadmium	mg/L	8	0.0001	0.0004	0.0002	0.0001
	Chromium	mg/L	8	<0.001	<0.001	<0.001	0.001
	Cobalt	mg/L	4	<0.001	<0.001	<0.001	0.001
	Copper	mg/L	8	0.001	0.0250	0.0091	0.001
	Iron	mg/L	8	0.097	0.27	0.167	0.005
	Lead	mg/L	8	<0.001	<0.001	<0.001	0.001
	Manganese	mg/L	8	<0.005	<0.005	<0.005	0.005
	Mercury	mg/L	8	<0.00005	<0.00005	<0.00005	0.00005
	Nickel	mg/L	8	<0.001	0.003	0.0013	0.001
	Selenium	mg/L	8	<0.003	<0.003	<0.003	0.003
	Vanadium	mg/L	4	0.001	0.010	0.0055	0.001
	Zinc	mg/L	8	0.005	0.078	0.0236	0.005

Analysed by SGS Cairns

Samples are collected throughout the year, but the water is usually only sourced from the Coen Dam after the Lankelly Creek dries up

**COOK SHIRE COUNCIL - DRINKING WATER QUALITY MANAGEMENT PLAN
ANNUAL REPORT**

Table 1.3F - Verification monitoring results (Raw Water) - Metals (Analysed by NATA Lab)

Sample Period 1/7/2015 - 30/6/2016

Source: Coen Bores

Scheme component	Parameter Metals	Units	Total No. samples collected	Min	Max	Average (Mean)	Limit of reporting
Raw Water	Arsenic	mg/L	3	0.003	0.007	0.005	0.003
	Barium	mg/L	3	0.000	0.013	0.012	0.005
	Beryllium	mg/L	3	<0.0001	<0.0001	<0.0001	0.0001
	Cadmium	mg/L	3	<0.0001	<0.0001	<0.0001	0.0001
	Chromium	mg/L	3	<0.001	0.001	<0.001	0.001
	Cobalt	mg/L	3	<0.001	<0.001	<0.001	0.001
	Copper	mg/L	3	0.001	0.014	0.008	0.001
	Iron	mg/L	3	0.005	0.089	0.047	0.005
	Lead	mg/L	3	0.001	0.006	0.004	0.001
	Manganese	mg/L	3	0.005	0.150	0.078	0.005
	Mercury	mg/L	3	<0.00005	<0.00005	<0.00005	0.00005
	Nickel	mg/L	3	0.001	0.003	0.002	0.001
	Selenium	mg/L	3	<0.003	<0.003	<0.003	0.003
	Vanadium	mg/L	3	0.001	0.003	0.002	0.001
	Zinc	mg/L	3	0.005	0.085	0.045	0.005

Analysed by SGS Cairns

Samples are collected throughout the year. The Coen Bores are usually only used as a backup supply

**COOK SHIRE COUNCIL - DRINKING WATER QUALITY MANAGEMENT PLAN
ANNUAL REPORT**

Table 1.3G - Verification monitoring results (Treated Water) - Physical Chemical (Analysed by NATA Lab)

Sample Period 1/7/2015 - 30/6/2016

Source: Treatment Plant Final

Scheme component	Parameter Physical / Chemical	Units	Total No. samples collected	Min	Max	Average (Mean)	Limit of reporting
Treatment Plant Final Water	Alkalinity as CaCO ₃	mg/L as CaCO ₃	5	10.0	30.0	19.80	5
	Calcium, Ca	mg/L	5	0.96	3.8	2.55	0.05
	Chloride, Cl	mg/L	5	17.0	21.0	18.6	1
	Colour Apparent	PCU	5	<5	5	<5	5
	Conductivity @ 25°C	uS/cm	5	92	160	120.8	5
	Fluoride, by ISE	mg/L	5	0.08	0.22	0.15	0.05
	L.I.		5	-3.40	-1.80	-2.52	-10
	Magnesium, Mg	mg/L	5	0.72	1.70	1.19	0.05
	pH	pH units	5	6.90	7.50	7.16	0.1
	Potassium, K	mg/L	5	0.76	1.30	1.13	0.05
	Salinity	mg/L	5	60.0	100.0	78.0	10
	SAR		5	2.20	3.10	2.50	
	Silica	mg/L	5	8.10	19.00	14.22	0.05
	Sodium, Na	mg/L	5	14.00	21.00	18.40	05
	Sulphate, SO ₄	mg/L	5	6.30	20.00	11.48	0.5
	TDS	mg/L	5	55.00	94.00	72.20	10
	Total Hardness	mg/L as CaCO ₃	5	5.0	16.0	11.0	1
Turbidity	NTU	5	<0.50	0.50	<0.50	0.5	

Analysed by SGS Cairns

**COOK SHIRE COUNCIL - DRINKING WATER QUALITY MANAGEMENT PLAN
ANNUAL REPORT**

Table 1.3H - Verification monitoring results (Treated Water) - Metals (Analysed by NATA Lab)

Sample Period 1/7/2015 - 30/6/2016

Source: Treatment Plant Final

Scheme component	Parameter Metals	Units	Total No. samples collected	Min	Max	Average (Mean)	Limit of reporting
Treatment Plant Final Water	Arsenic	mg/L	10	<0.003	<0.003	<0.003	0.003
	Barium	mg/L	2	0.014	0.0170	0.0155	0.005
	Beryllium	mg/L	2	<0.0001	0.0050	0.0001	0.0001
	Cadmium	mg/L	10	<0.0001	0.0002	<0.0001	0.0001
	Chromium	mg/L	10	<0.001	<0.001	<0.001	0.001
	Cobalt	mg/L	2	<0.001	<0.001	<0.001	0.001
	Copper	mg/L	10	<0.001	0.008	0.0036	0.001
	Iron	mg/L	8	<0.005	<0.005	<0.005	0.005
	Lead	mg/L	10	<0.001	<0.001	<0.001	0.001
	Manganese	mg/L	8	<0.005	<0.005	<0.005	0.005
	Mercury	mg/L	10	<0.00005	<0.00005	<0.00005	0.00005
	Nickel	mg/L	10	<0.001	<0.001	<0.001	0.001
	Selenium	mg/L	10	<0.003	<0.003	<0.003	0.003
	Vanadium	mg/L	2	<0.001	<0.001	<0.001	0.001
	Zinc	mg/L	9	<0.005	0.012	0.006	0.005

Analysed by SGS Cairns

**COOK SHIRE COUNCIL - DRINKING WATER QUALITY MANAGEMENT PLAN
ANNUAL REPORT**

Table 1.3I - Verification monitoring results (Treated Water) - Metals (Analysed by NATA Lab)

Sample Period 1/7/2015 - 30/6/2016

Source: Treatment Plant Final

Coen	Parameter	Units	Total No. samples collected	No. of samples in which parameter was detected	No. of samples exceeding water quality criteria
Reticulation	Coliforms / E.coli				
	Coliforms	MPM / 100 ml	153	2	0
	E.coli	MPM / 100 ml	153	0	0

Analysed by SGS Cairns

COOK SHIRE COUNCIL - DRINKING WATER QUALITY MANAGEMENT PLAN ANNUAL REPORT

Table 2 - Reticulation *E. coli* verification monitoring

Drinking water scheme: Coen

Year	2016 / 2017											
Month	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun
No. of samples collected	12	15	12	16	13	12	10	15	12	12	15	12
No. of samples collected in which <i>E. coli</i> is detected (i.e. a failure)	0	0	0	0	0	0	0	0	0	0	0	0
No. of samples collected in previous 12 month period	150	152	149	153	154	153	154	157	156	156	159	156
No. of failures for previous 12 month period	0	0	0	0	0	0	0	0	0	0	0	0
% of samples that comply	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%
Compliance with 98% annual value	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES

CALCULATE PERCENTAGE USING A TWELVE (12) MONTH 'ROLLING' ANNUAL VALUE

The *Public Health Regulation 2005* (the regulation) requires that 98 per cent of samples taken in a 12 month period should contain no *E. Coli*. This requirement is referred to as the 'annual value' in Schedule 3A of the regulation.

This requirement comes into effect once you have 12 months data and should be assessed every month based on the previous 12 months data (so that it is a 'rolling' assessment).

Coen's rolling average for E.coli compliance is 100%, in every month of the reporting period

**COOK SHIRE COUNCIL - DRINKING WATER QUALITY MANAGEMENT PLAN
ANNUAL REPORT**

Appendix B – Implementation of the DWQMP Risk Management Improvement Program

Progress in implementing the risk management improvement program

Existing Risk Management Improvement Program with “Progress to Completion” column added

Scheme Component / Sub-component	Hazard/ Hazardous event	Priority	Action(s)			Target date/s	Progress to Completion
			interim	short-term	long-term		
Sodium Hypochlorite dosing	Only one dosing pump No duty / Standby arrangement	High	Maintain monitoring of Chlorine Residual at Treatment Plant	Maintain a new pump on site at all times and maintain stocks of spare parts	Install a second dosing pump with associated wiring, or switchboard alterations	Short term – Costings June 2014 (Inclusion in 2015-16 Budget) Completion - May 2016	Completed
Loss of Mains Power (No power utility network damage)	Periods of loss of mains power	High	Rely on the Ergon Energy Generators located in Coen		Purchase of suitable sized generator / investigate alternative power sources	June 2018	Maintaining the Interim actions as listed No Further progress on the long term actions
Loss of Mains Power (Due to natural Disaster/s)	Extended periods of No mains Power due to power utilities distribution network severely damaged	High	N.A.	Hire of suitable sized generator if power not available at the Treatment Plant	Purchase of suitable sized generator / installation of alternative power sources	June 2018	
Staff	Loss of Key & Trained Staff	High	Maintain existing recruitment practices	Offer further training within their field to try and encourage employees to develop and attain certification certificates so that positions can be filled from “In House”		On Going	A recent Council “Restructure” saw 3 Water operations staff members with nearly 30 years combined experience, including 2 with Cert 3 in “Water & Wastewater Operations” lost to Redundancy
Operational & Maintenance Procedures	N.A	Medium	Identify outdated procedures, update and obtain approval and implement	Identify new procedures needed, develop and obtain approval and implement		Dec 2018	Some procedures have been developed, but more are required CSC Recently rolled out the new SafePlan throughout the Shire

**COOK SHIRE COUNCIL - DRINKING WATER QUALITY MANAGEMENT PLAN
ANNUAL REPORT**

Appendix C – Implementation of the 2016/17 Budgeted Capital Works Improvement Program

Progress in implementing the 2016/17 Budget Capital Works improvement program

Capital Works Item	Priority	Completion Target Date	Progress to Completion
Full Refurbishment of the Micro-Filtration Plant	High	Completion - June 2017	Completed
Replacement of the Bore 10 Tank and associated Pipework	Med.	Completion - June 2017	Not yet Started
Stage 1 SCADA System with associated Alarming	High	Completion - June 2017	Started, not yet Completed
Valve and Fire Hydrant replacement of aging infrastructure	Med.	Completion - June 2017	Started, not yet Completed